

Pricing for the Optimal Coordination of Opportunistic Agents

Ozgun Dalkilic, Atilla Eryilmaz, and Xiaojun Lin

Abstract—We consider a system where a load aggregator (LA) serves a large number of small-sized, economically-driven consumers with deferrable demand, as envisioned in smart electricity grid and data networks. In these systems, consumers can behave opportunistically by deferring their demand in response to the prices, to obtain economic gains. However, if not controlled properly, such opportunistic behavior can be detrimental to the system by creating aggregate effects that lead to undesirable fluctuations in price and total load.

To avoid the unwanted effects of demand-side flexibilities and to reap system-wide benefits from them, we propose two novel real-time dynamic pricing algorithms. The first algorithm communicates individual prices to consumers by adding small random perturbations to a common price. The second algorithm introduces a secondary price that penalizes the change in users' consumption in time. The common feature of both algorithms is creating differentiation among consumers and thus regulating the aggregate load. We conduct comprehensive numerical investigations and show that both the LA and the consumers economically benefit under the proposed pricing schemes.

I. INTRODUCTION

IN this work, we aim to design real-time dynamic pricing strategies for large systems where the demands possess various types of flexibilities. Demand-side flexibilities arise in systems such as smart electricity grids and cloud computing services. In these systems, flexibilities can materialize in various forms including, but not limited to, shifting or deferring service in time, giving intermittent service, and controlling the service amount. Consumers, who are inherently self-interested and economically-driven, will naturally want to alter their consumption behavior to take advantage of these flexibilities. Such consumer behavior induced by demand-side flexibilities brings both opportunities and challenges, and necessitates the design of novel management techniques.

We consider a system where a large number of *small self-interested consumers with flexible demand* are served by a *load aggregator (LA)*. Specifically, we use the retail-level smart electricity grid as an example. The consumers can be households with smart electrical devices, or small manufacturers, whereas the LA can be an electricity retailer. The type of demand-side flexibility that is considered in this paper is the ability to defer demand in time. For instance, smart air conditioners and washing machines can operate in this fashion. We assume that the consumers are not under the direct control of the LA, i.e. they independently decide on their consumption based on their individual economic interests and service requirements. Furthermore, in contrast to an offline formulation of the problem where future demand

is assumed to be known in advance, we consider the *real-time* control problem for the LA, where future demand can exhibit uncertain dynamics. We further note that the model in this paper can be applied to various scenarios such as a cloud computing center serving customers with computational tasks.

From the LA's perspective, demand-side flexibilities can be utilized to the advantage of the system operation. For example, in a smart electricity grid [1], or in a computer network [2], consumer demand can be deferred to a later time to cut peak load and to reduce service and maintenance costs. On the other hand, from consumer's perspective, flexibilities can be exploited to obtain economic benefits by reducing payments [3]. Towards this end, this work aims to design real-time pricing schemes to be implemented by an LA that *incentivize* economically-driven agents to *defer* their flexible demand so that system-wide benefits can be obtained.

However, pricing-based dynamic control of self-interested users also raises challenges. Under a time-dependent pricing scheme, consumers will likely defer their service to the periods of time with lower price in an opportunistic manner. Indeed, works such as [4], [5] establish optimality of threshold-based consumption policies, that have this opportunistic flavor, under different flexibility and cost structures. But, aggregate response of a large consumer base employing such threshold policies can potentially lead to highly- and abruptly-fluctuating total load and price (as will be demonstrated in Section III). In most systems, this volatile behavior is undesirable, because it increases service costs, puts stress on the network, and endangers the stability of the infrastructure [6]. Thus, in designing new pricing mechanisms, we aim to mitigate the mentioned effects of opportunistic behavior of flexible consumers.

Previous related work on demand-side management, which address the aforementioned opportunities and challenges related to demand-side flexibilities, and their fundamental differences from this work are listed below. In [7]–[9], the welfare maximization problem of an LA is studied under a utility maximization framework at day-ahead and real-time time-scales. However, consumers are assumed to have strictly concave utility functions, which result in smoother user behavior, and hence do not capture the above-mentioned volatility and fluctuation exhibited from the opportunistic decision making of self-interested users with deferrable demand. Game theoretic approaches are discussed in [10], [11] for incentivizing time-shifting of energy consumption, but the resulting mechanisms require the knowledge of all consumers' demand and utility which is unrealistic when the system is large. Furthermore, [12] considers an LA's problem of renewable supply integration via load scheduling, and formulate a Markov Decision problem. However, the solution requires the precise knowledge of the probabilistic distribution of future uncertainty.

Thus, a key difference of this work from the aforementioned

O. Dalkilic and A. Eryilmaz ({dalkilic.1, eryilmaz.2}@osu.edu) are with the Electrical and Computer Engineering Department at the Ohio State University, and X. Lin (linx@ecn.purdue.edu) is with the School of Electrical and Computer Engineering at Purdue University.

literature is that we consider the opportunistic decision-making of self-interested consumers, with deferrable demand, without relying on assumptions of strictly-concave utility functions or known probabilistic distributions. As in [4]–[6], we directly capture the behavior of such users through threshold policies, which however have been found to lead to system-level volatility. We then explicitly address such volatility through two new pricing mechanisms. Specifically, note that our preliminary investigations (Section III) show that consumption decisions of flexible consumers under a threshold policy get synchronized when all consumers face a common price signal. Motivated by this observation, the key idea in designing our new pricing algorithms is to create differentiation either in price or in agents’ internal states. Our first algorithm creates information asymmetry among users by sending *individual prices* to users obtained by creating small perturbations around a common price (Section IV). This scheme is appropriate when there are a large number of consumers, and it preserves long-term fairness among users although each user sees slightly different prices at each time period. On the other hand, the second algorithm introduces heterogeneity among users by imposing a common secondary price for the *change in consumption* of each user in time (Section V). This scheme is appropriate for both small and large systems, and it does not differentiate users based on the price they see.

Technically, both of the proposed algorithms solve variations of the same cost minimization problem, which are obtained by augmenting the objective of the original problem with convex terms. Furthermore, our results (Section VI) convey the prominent message that introducing differentiation among opportunistically behaving agents alleviates the detrimental effects of the feedback loop between aggregate load and price. In particular, under the proposed algorithms (i) high volatility and instability problems are alleviated; (ii) a flatter load pattern, which is less costly to supply, is achieved; (iii) flexible consumers obtain economic benefits.

II. SYSTEM MODEL AND PROBLEM FORMULATION

We consider a system where a load aggregator (LA) serves a large number of small consumers. In the following, we present a generic real-time model and introduce the system participants. Then, we focus on the smart electricity grid and formulate the control and pricing problem.

A. System Model

The system is operated over discrete time periods, $t = 0, 1, \dots$, and at each time period the participants make their control decisions. The system comprises an LA and a large number of consumers as depicted in Figure 1. The LA sets the real-time prices for its consumers, and ensures that consumers’ loads are served upon their request. The goal of the LA is to maximize its profit. On the other hand, consumers seek to satisfy their demand with the aim of making the lowest payment for consumption. There are two types of consumers in the system. *Flexible* consumers have deferrable demand, i.e. they can delay their consumption. *Inflexible* consumers, however, cannot delay their consumption and must serve their

demand at the time the demand is realized. The system model described is a closed-loop feedback stochastic dynamical system. Consumers react to the price generated by the LA in real-time, and the LA adjusts the price based on the total load. Next, we present the participants and the operation of the system in detail, using electricity system as a specific example.




Fig. 1. The system model depicting the participants and their interactions.

1) *Load Aggregator (LA)*: The LA serves its customers by procuring electricity via purchasing from a wholesale market or a distributor. The procurement of s watts of power incurs cost $C(s)$ to the LA. Note that, the cost function C encapsulates the payments for purchasing electricity as well as maintenance and capital costs [7], [8], [10], [11], [13], [14]. We assume that $C : \mathbb{R}^+ \rightarrow \mathbb{R}^+$ is a continuously differentiable and increasing function of s . We also assume that $\dot{C}(s) \geq c_c > 0$ for all $s \geq 0$, and hence C is strongly convex and \dot{C} is invertible.

The LA intends to coordinate its customers by setting the real-time prices at each time period, i.e. $p(t)$ for $t = 0, 1, \dots$. The price is generated *ex-ante*, meaning that the amount of consumption is unknown at the time the price is set. Based on the price it sets, the LA receives the payment $\omega(t) \triangleq p(t)s(t)$. Hence, the LA’s goal is to maximize its profit $\omega(t) - C(s(t))$. Furthermore, the LA does not have the knowledge of consumer valuations and their control strategies.

2) *Consumers*: There are N flexible and N_i inflexible consumers. At period t , consumer n generates demand $a_n(t)$. $a_n(t)$ is a random variable that is assumed to be independent among consumers and i.i.d. over time. The average demand generation rate is λ_n , and $\mathbb{E}[A_n(t)] = \lambda_n$ for all t . We assume that demand is bounded such that $A_n(t) \in [0, a_{n,max}]$. The energy consumption, namely *load*¹, by user n at period t is denoted by $x_n(t) \in [0, \bar{x}_n]$. For inflexible consumers, $x_n(t) = a_n(t)$ because the realized demand must be served immediately. We define $S_i(t) \triangleq \sum_{n=1}^{N_i} x_n(t)$, with mean $\lambda_S = \sum_{n=1}^{N_i} \lambda_n$, to be the total load of inflexible users. For flexible consumers, the amount of electric energy consumption is not necessarily equal to the amount of realized demand; Realized demand can be deferred and served later as load.

The waiting queue for flexible consumer n ’s deferrable demand at time t is $q_n(t)$ and its evolution is given by

$$q_n(t+1) = [q_n(t) + a_n(t) - x_n(t)]^+ \quad (1)$$

where $[z]^+ \triangleq \max\{z, 0\}$. These queues are required to be stable, otherwise the delay experienced by the demand will approach infinity. The goal of flexible consumer n is to minimize its payment, $r_n(t) \triangleq p(t)x_n(t)$, under the queue

¹To be precise: “Demand” is externally generated according to a , but can be delayed. “Load” is the actual consumption at each time period.

stability constraint. Inflexible consumers do not have such objective since they do not have control on their load.

B. Problem Formulation

In the paper, we use boldface letters to denote vectors, e.g. $\mathbf{x} = (x_1, \dots, x_N)$ is the N dimensional vector of the scalar quantities x_n for $n = 1, \dots, N$. We use $\{\cdot\}$ to denote a set of quantities whose size should be understood from context.

The optimization problem we consider is the LA's cost minimization problem:

$$\min_{\{\mathbf{x}(t)\}\{s(t)\}} \lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=0}^{T-1} \mathbb{E}[C(s(t))] \quad (2)$$

$$\text{s.t.} \quad \sum_{n=1}^N x_n(t) + S_i(t) = s(t), \quad \forall t = 0, 1, \dots \quad (3)$$

$$\lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=0}^{T-1} \mathbb{E}[x_n(t)] \geq \lambda_n, \quad \forall n. \quad (4)$$

In problem (2), objective is the time averaged expected cost of electricity procurement. Constraint (3) ensures that consumer load is served completely, constraint (4) ensures that the flexible consumers experience finite delay.

Instead of Problem (2), we will consider the following static (one time-period) problem:

$$\min_{\mathbf{x}, s} C(s) \quad \text{s.t.} \quad \sum_{n=1}^N x_n + \lambda_S \leq s \quad (5)$$

$$\lambda_n \leq x_n, \quad \forall n.$$

It can be shown that the optimum objective value of (5) is a lower bound for that of (2) due to the convexity of C . Hence, by providing a solution to problem (5), which satisfies the constraint (4) and matches supply to load, we can achieve an objective value that is close to the optimum value of problem (2).

Problem (5) is easy to solve and various iterative algorithms can be developed to achieve the optimum solution. However, such algorithms may dictate undesirable control-rules on the consumer side that do not align with flexible consumers' objective of minimizing their payments. On the other hand, as we will show in Section III-B, allowing flexible consumers to fully exhibit their opportunistic behavior may cause instability and inefficiency by generating abrupt changes and fluctuations in power generation. Therefore, our goal is to design control and real-time pricing schemes that will give flexible consumers the freedom to opportunistically consume electricity for their own interest, and that will also achieve the minimum or close-to-minimum electricity procurement cost.

III. FLEXIBLE CONSUMER BEHAVIOR AND BENCHMARK REAL-TIME PRICING SCHEMES

In the following, we will first characterize the flexible consumer behavior, and then discuss its impact on the system performance. To demonstrate the detrimental effects of consumer-side flexibility, we present two simple and intuitive real-time pricing schemes that will also serve as benchmarks when assessing our own pricing schemes' performance.

A. Flexible Consumer Behavior

In our model, consumers are price-taking; At period t , each consumer receives a price $p(t)$ for consuming unit amount of power, and then decides on his load. Thus, the optimization problem faced by a flexible consumer can be formulated as

$$\min_{\{x_n(t)\}} \lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=0}^{T-1} \mathbb{E}[p(t)x_n(t)] \quad (6)$$

$$\text{s.t.} \quad \lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=0}^{T-1} \mathbb{E}[x_n(t)] \geq \lambda_n, \quad \forall n.$$

From a single consumer's perspective, his individual load decisions have negligible effect on the future prices when the number of users is large. Hence, we assume that $p(t)$ is exogenous; It is independent of $x_n(t)$ in problem (6). Under this assumption, the following policy achieves the optimal value of (6) in asymptotic regime where the design parameter κ_n approaches to 0:

$$x_n(t) = \bar{x}_n \mathbb{1}\{p(t) \leq \kappa_n q_n(t)\} \quad (7)$$

We note that this threshold policy and similar threshold-based policies have been shown to be asymptotically optimal when the prices are exogenous [4], [15], [16].

The policy in (7) results in an opportunistic behavior. Users consume electricity only when price is below a certain threshold, and when they consume they put their maximum load \bar{x}_n to take full advantage of the low price. However, this behavior, when aggregated over a large consumer base, will cause very high (low) load when price is low (high). Thus, as we will see subsequently, the resulting load pattern will not be flat and will be costly to supply. Furthermore, supply and price will be highly fluctuating since the price is adjusted in real-time by the LA as a response to the changes in load.

B. Benchmark Real-time Pricing Schemes

i) Scheme I (Real-time Pricing With Zero Flexible Consumer Penetration): In this scheme, all consumers are inflexible, so they do not have the ability to defer their loads; Arriving demand is served immediately, i.e. $x_n(t) = a_n(t)$ for all n . On the other hand, the LA uses $\sum_n x_n(t)$ as the prediction of the load on the next time period, and sets the price to the total marginal procurement cost, i.e. $p(t+1) = \dot{C}(s(t))$ subject to $s(t) = \sum_n x_n(t)$. This choice of price maximizes the LA's profit assuming that the load prediction is accurate. To summarize, Scheme 1 is given as follows:

Scheme 1. At time t :

- Consumer n sets $x_n(t) = a_n(t)$.
- The LA computes:

$$p(t+1) = \dot{C}(s(t)), \quad \text{s.t.} \quad s(t) = \sum_n x_n(t) + S_i(t)$$

We note that Scheme 1 serves as a base setup, which will be useful in assessing both the advantages and disadvantages of consumer-side flexibility.

ii) Scheme II (Gradual Real-time Price Update under Flexible Consumer Presence): Under his scheme, a percentage

of users have flexible demand. We assume that these users implement the threshold policy (7). Due to (7), we expect the aggregate load to become either very large or too small, since the consumers use the maximum amount x_n^m or nothing based on the common price. Thus, in order to prevent fluctuations in price in response to the total load, this scheme iteratively updates the price instead of setting it to the marginal cost of the total load. Scheme 2, which updates the price based on the dual of problem (5), is presented below.

Scheme 2. At time t :

- Consumer n computes (1) and

$$x_n(t) = \bar{x}_n \mathbb{1}\{p(t) \leq \kappa_n q_n(t)\} \quad (8)$$

- The LA must meet the real load $\sum_n x_n(t) + S_i(t)$. Further, it computes $s(t) = \dot{C}^{-1}(p(t))$, and updates the price:

$$p(t+1) = \left[p(t) + \kappa^s \left(\sum_n x_n(t) + S_i(t) - s(t) \right) \right]^+ \quad (9)$$

Under Scheme 2, although the price exhibits relatively small oscillations due to the dampening effect of κ^s , the total load abruptly fluctuates as seen in Figure 2. Figure 2 also depicts the same amount of total load under Scheme 1. Note that although Scheme 1 does not have the fluctuation problem as Scheme 2, it does not take advantage of the demand flexibilities either. Under the presence of demand flexibilities, the key problem appears to be that the customers, who implement the threshold policy (7), respond to a common price in a synchronous manner. In the following sections, we will propose pricing schemes that will resolve this synchronization problem by introducing differentiation among consumers.




Fig. 2. Load under Scheme 1 and 2: Flexible consumers receive Poisson distributed demand arrivals, and their load constitute 5% of the total load.

IV. RANDOMIZED PRICING (RP) ALGORITHM

RP algorithm aims to mitigate the volatility and instability problems that can arise due to the opportunistic behavior of flexible consumers. Towards this goal, the underlying motivation in the design of RP is twofold. First, we consider updating the common price incrementally so that sudden changes in load do not directly translate as large fluctuations in price. Second, in order to prevent flexible consumers' load decisions from aligning together (which creates peaks and valleys in the aggregate load), we differentiate the price over the consumer base. In particular, each consumer receives an individual price that is randomly differentiated from the common price.

It should be noted that the randomized pricing scheme respects both economical fairness and consumer experience while creating differentiation among consumers. From the

economic perspective, RP is fair to identical users. As we will show in this section, through independent randomizations over time and over users, we assure that time average of prices that users receive are fair; averaged over time, no user receives a higher or lower price than another user with the same demand characteristics. From the consumer perspective, users are always in complete control as RP lets users choose their time-of-service based on both the price signals and their own preferences (e.g., in terms of how much they are willing to wait). An example of contrast regarding user experience is the randomized delay scheme where consumers' service are delayed by the utility for random amounts of time in order to prevent consumer loads from aligning together in time. Under this scheme, users do not have control on when their demand is served after they make their decision to get service. Hence, randomized delay schemes distort the users' perception of service quality, because the users no longer have an accurate sense of the overall delay experienced by their demand.

The real-time randomized pricing algorithm is given in Algorithm RP. In Algorithm RP, individual prices are generated by adding to the common price i.i.d. random noise $\epsilon_n(t)$, which has the CDF (Cumulative Distribution Function) F_ϵ . The additive perturbations can have an arbitrary distribution as long as F_ϵ satisfies Assumption 1, which ensures that F_ϵ has an inverse function.

Assumption 1. F_ϵ is continuous on its domain and strictly increasing from 0 to 1 on an interval $[\epsilon_{min}, \epsilon_{max}]$.

Algorithm RP Randomized Pricing Algorithm

At iteration t :

- Consumer n receives an individual price $p_n(t)$. Then, it computes its queue as in (1) and load as

$$x_n(t) = \bar{x}_n \mathbb{1}\{p_n(t) \leq \kappa_n q_n(t)\} \quad (10)$$

- The LA must meet the real load $\sum_n x_n(t) + S_i(t)$. Further, it computes $s(t) = \dot{C}^{-1}(p(t))$, and updates the common price:

$$p(t+1) = \left[p(t) + \alpha \left(\sum_{n=1}^N x_n(t) + S_i(t) - s(t) \right) \right]^+$$

Then, the LA generates individual prices that are communicated to each consumer separately:

$$p_n(t+1) = p(t+1) + \epsilon_n(t+1)$$

where $\epsilon_n(t)$ are i.i.d. random variables over time and consumers with the CDF F_ϵ .

Under Algorithm RP, users pay for their consumption at the individual price that is privately communicated to them by the LA. Since this price is generated by adding a random disturbance to the common price, the revenue obtained at each time period will be different from the revenue anticipated by the LA. Hence, it is not surprising that RP does not achieve the optimal solution to problem (2). Instead, we will show that RP achieves the optimal solution to a welfare maximization problem that is closely related to the original problem. The basic idea is that communicating randomized

prices to consumers induces a utility-function based decision at the consumer side. To demonstrate this, we first present a continuous-time fluid approximation of RP which will also be instrumental in analyzing its optimality and convergence. Then, we present the analysis of RP in discrete-time in the next subsection.

A. Continuous-time Fluid Approximation Model and Utility-Maximization-Based Formulation

In this section we derive a continuous-time fluid approximation for algorithm RP [17]. Then, we relate the model to a utility maximization problem with modified consumer utility functions induced by price randomization.

The aggregate flexible consumer load is the sum of N binary variables, i.e. $X(t) \triangleq \sum_n \bar{x}_n \mathbb{1}\{\epsilon_n(t) \leq \kappa_n q_n(t) - p(t)\}$. Moreover, conditioned on $p(t)$ and $q_n(t)$, each $x_n(t)$ is independent since ϵ_n are independent. Applying the Law of Large Numbers based on this assumption, we obtain the following expression for the aggregate load

$$X(t) \approx \sum_n \bar{x}_n F_\epsilon(\kappa_n q_n(t) - p(t)). \quad (11)$$

The above expression is the mean behavior for the aggregate load, and when the number of users is large it will well approximate the dynamics of the load.

We define $u_n(x) \triangleq \bar{x}_n F_\epsilon(-x)$, and write

$$x_n(t) \approx u_n(p(t) - \kappa_n q_n(t)),$$

which approximates the mean behavior of individual users. Next, we present a continuous-time approximation to RP.

Algorithm RP-C Continuous-time Approximation to RP

$$x_n(t) = \bar{x}_n F_\epsilon(\kappa_n q_n(t) - p(t)) \quad (12)$$

$$s(t) = \dot{C}^{-1}(p(t)) \quad (13)$$

$$\dot{q}_n(t) = \begin{cases} \lambda_n - x_n(t) & \text{if } q_n(t) > 0, \text{ or} \\ & \lambda_n - x_n(t) \geq 0 \\ 0 & \text{otherwise} \end{cases}$$

$$\dot{p}(t) = \begin{cases} \alpha \left(\sum_{n=1}^N x_n(t) + \lambda_S - s(t) \right) & \\ \text{if } p(t) > 0, \text{ or} & \\ \sum_{n=1}^N x_n(t) + \lambda_S - s(t) \geq 0 & \\ 0 & \text{otherwise} \end{cases}$$

In (RP-C), consumer loads are computed via the smooth functions u_n . Since F_ϵ is continuous and strictly increasing on $[\epsilon_{min}, \epsilon_{max}]$, u_n is continuous and strictly decreasing, and it has an inverse u_n^{-1} . The domain of u_n^{-1} is the interval $[0, \bar{x}_n]$. We define function U_n such that $\dot{U}_n(x) \triangleq u_n^{-1}(x)$ on $(0, \bar{x}_n)$, which exists since $u_n^{-1}(x)$ is continuous, and hence integrable. Explicitly

$$\dot{U}_n(x) \triangleq \int u_n^{-1}(x) dx, \text{ for } x \in [0, \bar{x}_n] \quad (14)$$

Note that by this definition, U_n is strictly concave on $[0, \bar{x}_n]$, i.e. there exists $c_u > 0$ such that $\dot{U}_n(z) \leq -c_u < 0$ for all z and n .

Having defined the functions U_n , we consider the following social welfare maximization problem

$$\min_{\mathbf{x}, s} C(s) - \sum_{n=1}^N U_n(x_n) \quad (15)$$

$$\text{s.t. } \sum_{n=1}^N x_n + \lambda_S \leq s \quad (16)$$

$$\lambda_n \leq x_n, \forall n \quad (17)$$

In (15), U_n can be interpreted as a consumer utility function. Problem (15) is quite similar to problem (5) only with a change in the objective function, where the utility of consumption is amended.

Define p to be the dual variable corresponding to (16), and q_n to be the dual variables corresponding to (17). Let $(\hat{\mathbf{x}}, \hat{s}, \hat{p}, \hat{\mathbf{q}})$ be the optimal primal-dual solution to problem (15). The next theorem shows that RP-C converges to the optimal solution of (15)-(17).

Theorem 1. *The continuous-time approximation algorithm RP-C converges to the optimal solution $(\hat{\mathbf{x}}, \hat{s}, \hat{p}, \hat{\mathbf{q}})$ of Problem (15).*

Proof. See Appendix A. □

Note that Theorem 1 gives insights on the *average* behavior of RP as we will see in Section VI. For the convergence and performance result on RP, we provide the discrete-time analysis of RP in the following.

B. Discrete-time Analysis of Algorithm RP

In the previous section, we observed that the continuous-time approximation of RP converges to the optimal solution of (15), which is closely related to the original problem (5) via the distribution of the price perturbations $\epsilon_n(t)$. In this section, we provide convergence results for RP in discrete time.

The following theorem shows that, under Algorithm RP, $s(t)$ and the price $p(t)$ get arbitrarily close to the corresponding optimum values of the modified problem (15), \hat{s} and \hat{p} respectively.

Theorem 2. *Under Algorithm RP, we have*

$$\lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=1}^{T-1} \mathbb{E} [(s(t) - \hat{s})^2] \leq \frac{B}{c_c} \quad (18)$$

$$\lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=1}^{T-1} \sum_n \mathbb{E} [(\tilde{x}_n(t) - \hat{x}_n)^2] \leq \frac{B}{c_u} \quad (19)$$

where B is a constant that depends on the step size α and user parameter κ_n , and $\tilde{x}_n(t) \triangleq u_n(p(t) - \kappa_n q_n(t))$.

Proof. See Appendix B. □

We have the following observations on Theorem 2:

i) The Effect of Price Randomization: Theorem 2 shows that the common price $p(t)$ and the average consumer load $x_n(t)$ get closer to the optimum values of problem (15), as c_c and c_u become large. Note that c_u is defined as $\dot{U}_n(x) \leq -c_u$ and we had $\dot{U}_n(x) = u_n^{-1}(x)$. Thus, the larger c_u is the less steep

the CDF F_ϵ is. For instance, for $\epsilon_n(t) \sim \mathcal{U}(-\epsilon, \epsilon)$, as ϵ gets larger c_u gets larger as well. Hence, increasing the amount of randomness on the common price decreases the bounds in (18) and (19). On the other hand, we should note that B is directly proportional to the second moment of $\epsilon_n(t)$; increasing the amount of randomness, increases B . Due to this two-sided effect of randomization on convergence results, the distribution for the disturbances added to the common price should be carefully chosen as we will observe in Section VI.

ii) Step Size α and Load Tracking Capability: The results show that α should be sufficiently small for better convergence because the bounding term B depends on α . On the other hand, too small a value of α may affect how the algorithm tracks the changes in the inflexible load $S_i(t)$. Specifically, if α is chosen to be too small, the price can lag behind $S_i(t)$, and consequently the flexible load can miss the valleys in the daily pattern. We note that this trade-off between convergence rate and tracking capability is common among iterative algorithms.

iii) Number of Flexible Users N and Fluctuations in Total Load: Theorem 2, in particular (19), suggests that $\tilde{x}(t)$ will be close to \hat{x}_n . Note that $\tilde{x}_n(t) = u_n(p(t) - \kappa_n q_n(t))$ and $\hat{x}_n = u_n(\hat{p} - \kappa_n \hat{q}_n)$. Thus, as $\alpha \rightarrow 0$ we get $(p(t) - \kappa_n q_n(t)) \rightarrow (\hat{p} - \kappa_n \hat{q}_n)$. In this regime, the consumption of individual customer is given by $x_n(t) = \bar{x}_n \mathbb{1}\{\epsilon_n(t) \leq \kappa_n q_n(t) - p(t)\} \approx \bar{x}_n \mathbb{1}\{\epsilon_n(t) \leq \kappa_n \hat{q}_n - \hat{p}\}$. Hence $x_n(t)$ are approximately independent random variables. Then, we can invoke Kolmogorov's Strong Law of Large Numbers, and argue that, as $N \rightarrow \infty$, we have with probability 1

$$\frac{1}{N} \sum_n x_n(t) - \frac{1}{N} \sum_n \bar{x}_n F_\epsilon(\kappa_n \hat{q}_n - \hat{p}) \rightarrow 0 \quad (20)$$

As a result, we can deduce that as the number of flexible users, N , increases, total flexible load tends to remain close to its average value.

V. CHANGE-OF-USE PRICING (COUP) ALGORITHM

In this section, we take a different approach and propose a new pricing scheme. The key idea is to penalize large variations in each consumer's load by introducing a secondary price. In particular, consumers are charged for an extra penalty based on the amount of change in their loads between consecutive time periods, while they still pay for their consumption at each time period at the primary price.

Pricing the change in load can be interpreted as another sort of differentiation among users. In this case, the secondary price introduces heterogeneity among consumption decisions of users. Intuitively, users will prefer changing their consumption more gradually depending on their internal states instead of consuming either the maximum \bar{x}_n or 0. We will show that our pricing algorithm coordinates users' consumption decisions in an asynchronous manner such that changes in users' loads cancel out to create a total load that is flat.

Under the new algorithm COUP, at each time t the common price $p(t)$ and the secondary price γ are announced. The payment at time t for a consumer with load $x_n(t)$ is

$$p(t)x_n(t) + \gamma(x_n(t) - x_n(t-1))^2.$$

Here, the second term is the new component that incurs a penalty (uniform across users and constant over time) on the change of load. Intuitively, this penalty encourages the users to smooth out their loads, and reduces the potential volatility. Having discussed the new pricing scheme, we present the new pricing mechanism in Algorithm COUP below.

Algorithm COUP Change-of-Use Pricing Algorithm

At iteration t :

- Consumer n receives the common price $p(t)$ and the penalty price γ . Then, it computes its queue as in (1) and load as

$$x_n(t) = \left[x_n(t-1) + \frac{1}{2\gamma} (\kappa_n q_n(t) - p(t)) \right]^+ \quad (21)$$

- The LA must meet the real load $\sum_n x_n(t) + S_i(t)$. Further, it computes $s(t) = \hat{C}^{-1}(p(t))$, and updates the price:

$$p(t+1) = \left[p(t) + \alpha \left(\sum_{n=1}^N x_n(t) + S_i(t) - s(t) \right) \right]^+$$

In COUP, (21) corresponds to the solution of the following optimization problem given the user's consumption in the previous period $t-1$:

$$\min_{x_n} \{ (p - \kappa_n q_n)x_n + \gamma(x_n - x_n(t-1))^2 \}. \quad (22)$$

Drawing direct comparison to RP and the threshold rule (10), we observe that without the second term, (22) is the same problem that a consumer solves under RP. Hence, the second term can be seen as the addition due to the penalty on the change in consumption. Furthermore, the price update rule in COUP is still the same as that in RP. Following a similar method as in the analysis of RP, we will show next that the continuous-time approximation of COUP achieves the optimal objective value of the original problem (5) by solving a closely related welfare maximization problem. In particular, the new welfare maximization problem differs from the original one in its objective, which involves the augmentation of a *proximal term* to the original objective due to the penalty term we introduced in the pricing mechanism.

A. The Continuous-Time Fluid Approximation Model and Welfare-Maximization-Based Formulation

The continuous-time fluid approximation model for COUP is straightforward to obtain and it is presented in Algorithm COUP-C. Similar to what we noted before for the discrete-time algorithms, COUP-C differs from RP-C only in the description of user consumption $x_n(t)$.

Next, we will show that COUP-C converges to a stationary regime where it achieves the optimal objective of the original problem (5). To this end, we augment the objective of problem (5) with an additional cost term motivated by the proximal optimization algorithm [18]. The resulting welfare-maximization problem is

$$\min_{\mathbf{x}, \mathbf{y}, s} C(s) + \gamma \sum_{n=1}^N (x_n - y_n)^2 \quad (27)$$

Algorithm COUP-C Continuous-time Approximation to COUP

$$\dot{x}_n(t) = \begin{cases} \frac{1}{2\gamma}(\kappa_n q_n(t) - p(t)) & \text{if } \begin{matrix} x_n(t) > 0, \text{ or} \\ \kappa_n q_n(t) - p(t) \geq 0 \end{matrix} \\ 0 & \text{otherwise} \end{cases} \quad (23)$$

$$\dot{q}_n(t) = \begin{cases} \lambda_n - x_n(t) & \text{if } \begin{matrix} q_n(t) > 0, \text{ or} \\ \lambda_n - x_n(t) \geq 0 \end{matrix} \\ 0 & \text{otherwise} \end{cases} \quad (24)$$

$$s(t) = \dot{C}^{-1}(p(t)) \quad (25)$$

$$\dot{p}(t) = \begin{cases} \alpha \left(\sum_{n=1}^N x_n(t) + \lambda_S - s(t) \right) & \\ \text{if } \begin{matrix} p(t) > 0, \text{ or} \\ (\sum_{n=1}^N x_n(t) + \lambda_S - s(t)) > 0 \end{matrix} & \\ 0 & \text{otherwise} \end{cases} \quad (26)$$

$$\text{s.t. } \sum_{n=1}^N x_n + \lambda_S \leq s \quad (28)$$

$$\lambda_n \leq x_n, \forall n, \quad (29)$$

where γ is a positive constant and $y_n \in \mathbb{R}$ are auxiliary variables. It is easy to see that if x_n^* and s^* are the optimal solution to problem (5), then $x_n = x_n^*$, $y_n = x_n^*$, and $s = s^*$ are trivially the optimal solution to problem (27). However, the quadratic term in (27) makes the problem strictly convex in x_n , which helps to alleviate volatility as we will see shortly. As in other proximal optimization algorithms [18], at each iteration we first fix $y_n(t)$ and optimize the objective of (27) over x_n . Let the corresponding optimal solution be $x_n(t)$. We then set $y_n(t+1) = x_n(t)$ and continue with the next iteration. By setting $y_n(t+1) = x_n(t)$, the quadratic term in (27) becomes $\gamma \sum_{n=1}^N (x_n(t) - x_n(t-1))^2$, which penalizes the difference in load between periods t and $t-1$.

We consider the Lagrangian function for problem (27) for fixed $y_n = x_n(t-1)$, and obtain the dual function as

$$D(p, \mathbf{q}) = \sum_{n=1}^N \min_{x_n} \{ (p - \kappa_n q_n) x_n + \gamma (x_n - y_n)^2 \} \\ + \min_{s \geq 0} \{ C(s) - ps \} + p \lambda_S + \sum_{n=1}^N \lambda_n q_n, \quad (30)$$

where $p \geq 0$ and $\mathbf{q} \triangleq [q_n \geq 0, n = 1, 2, \dots, N]$ are the dual variables corresponding to the constraints (28) and (29), respectively. The first optimization in (30) is the users' optimization problem (22) whose solution gives the consumption update rule (21) of COUP. The second optimization in (30) is the profit maximization for the LA. Furthermore, inspecting the dual problem reveals that COUP-C corresponds to the dual algorithm for problem (27). Specifically, the primal variables \mathbf{x} , s and the dual variables p , \mathbf{q} are updated at each iteration first with \mathbf{y} kept fixed, and then \mathbf{y} is updated at the end of each iteration by setting $\mathbf{y}(t+1) = \mathbf{x}(t)$. Thus, $y(t)$ is dropped from the algorithm description and is replaced with $x(t-1)$.

Having established the relation between COUP-C and problems (5) and (27), we can study the convergence and optimality of COUP-C. Before doing so, we give the definition of the stationary point for the sum of variables.

Definition 1. Define $\Phi(t) \triangleq (\sum_n x_n(t), \sum_n q_n(t), p(t), s(t))$. $\Phi^* \triangleq (X^*, Q^*, p^*, s^*)$ is a stationary point of COUP and COUP-C in the sum sense, if $\Phi(t_0) = \Phi^*$ for some $t_0 < \infty$ and $\Phi(t) = \Phi(t_0)$ for all $t > t_0$.

Note that, Φ^* may not achieve the optimal objective of problem (27) since we use $x_n(t-1)$ in place of $y_n(t)$. However, if Φ^* satisfies $p^* = \dot{C}(s^*)$, $s^* = X^* + \lambda_S$, $X^* = \sum_n \lambda_n$, then Φ^* achieves the optimal objective of problem (5). The next theorem shows that the system of equations given in COUP-C converges to the stationary state as described in Definition 1, where Φ^* achieves the optimal objective of (5).

Theorem 3. In the system characterized by Algorithm COUP-C, $\Phi(t)$ converges to a stationary point Φ^* , which achieves the optimal objective value of problem (5).

Proof. See Appendix C. \square

Theorem 3 shows that the aggregate flexible load, $\sum_n x_n(t)$ converges to X^* . Thus the main observation that we draw from the theorem is that the oscillations in the price and the total load become arbitrarily small under COUP-C.

B. Discrete-time Analysis of Algorithm COUP

This section presents the analysis of COUP in discrete-time. In particular, Theorem 4 shows that $s(t)$ and the price $p(t)$ get arbitrarily close to s^* and p^* , respectively, the optimum values of the original problem (5).

Theorem 4. Under Algorithm COUP, we have

$$\lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=1}^{T-1} \mathbb{E} [(s(t) - \hat{s})^2] \leq \frac{B}{c_c} \quad (31)$$

$$\lim_{T \rightarrow \infty} \frac{1}{T} \sum_{t=1}^{T-1} \sum_n \mathbb{E} [(x_n(t) - x_n(t-1))^2] \leq \frac{B}{\gamma} \quad (32)$$

where B is a constant that depends on the step size α and user parameter κ_n .

Proof. See Appendix D. \square

Theorem 4 further states that the differences in individual consumers' loads between consecutive time slots decrease with increasing penalty factor γ . Thus, as anticipated, sufficiently large values of γ dampens the fluctuations in the total flexible load and the price. Furthermore, as in the case of RP and Theorem 2, we can make similar observations regarding the step size α and the algorithm's load tracking capability.

VI. PERFORMANCE AND NUMERICAL RESULTS

We now provide numerical results that demonstrate the desirable features of the proposed algorithms. The performance metrics that we consider are the payments made by the consumers and the cost of generation. In terms of these metrics, we compare the performance of RP and COUP to the benchmark schemes. In the rest of this section, the following simulation setup is used unless otherwise is stated: LA cost is set to be $C(s) = \frac{s^2}{2}$. Flexible consumers receive Poisson

distributed random arrivals. In RP, $\epsilon_n(t) \sim \mathcal{U}(-\epsilon, \epsilon)$ for all t . In COUP, $\kappa_n = 1$ and $\alpha = 0.01$.

First, we present the algorithms' behavior over time. In Figure 3, load evolutions obtained by running RP and COUP are plotted for two days. There are 1000 flexible consumers and their total average load is set to be 5% of the total load. Historical metered load data from PJM is used as inflexible load [19]. In Figure 3, we observe a *waterfilling* behavior that results in a smoother load pattern (c.f. Figure 2); Flexible users consume electricity when the inflexible demand is low (i.e. when the average price is low) and fill the valleys in the daily pattern. The effect of price differentiation by randomization among flexible users shows up as the random zigzag pattern for RP. On the other hand, total load is smoother under COUP as deduced from (32) in Theorem 4.




Fig. 3. Waterfilling behavior of the aggregate grid load. In RP, ϵ is set to be 1% of the average price. In COUP, γ is set to be 1% of the average price.

A. Consumer and LA Payments

The payment made by consumer n in RP-C is given by

$$r_n(t) = p(t)x_n(t) + x_n^m \mathbb{E} \left[\epsilon_n \mathbb{1} \left\{ \epsilon_n \leq -\dot{U}(x_n(t)) \right\} \right]$$

which follows from (12). On the other hand, the LA anticipates the payment $w(t) = p(t)s(t)$, since it sets $p(t)$ based on the computed value of $s(t)$. At the equilibrium of Algorithm RP-C, the supplier and total consumer payments are given by

$$\hat{r} = \hat{p} \sum_n \hat{x}_n + \sum_n x_n^m \mathbb{E} \left[\epsilon_n \mathbb{1} \left\{ \epsilon_n \leq -\dot{U}(\hat{x}_n) \right\} \right] \quad (33)$$

$$\hat{w} = \hat{p}\hat{s} = \hat{p} \sum_n \hat{x}_n \quad (34)$$

where (34) follows from the KKT condition in (39).

On the other hand, under COUP-C, an individual consumer's payment does not achieve a constant equilibrium value due to the sum convergence result in Theorem 3. Instead, consumer payment has the following time-varying limit when the system is in the stationary regime given in Definition 1:

$$r_n(t) = \hat{p}x_n(t) + \gamma (x_n(t) - x_n(t-1))^2 \quad (35)$$

Therefore, total consumer payment is also time-varying, and is given by

$$r(t) = \hat{p}X^* + \gamma \sum_n (x_n(t) - x_n(t-1))^2 \quad (36)$$

Besides, supplier payment under COUP-C achieves a constant value in the stationary state as it does under RP-C

$$\hat{w} = \hat{p}\hat{s} = \hat{p}X^* \quad (37)$$

Comparing (33) to (34), and (36) to (37), we observe that the amount of payment received from flexible consumers and

the amount of anticipated payment computed by the supplier do not necessarily match. The differences between consumer and supplier payments are given by the second terms in (33) and (36). We call this difference the *LA deficit*. Note that the LA deficit is always positive for COUP-C because of the secondary price γ , whereas under RP-C, the deficit can be either negative or positive depending on the distribution of ϵ_n .

Naturally, one wants to make the LA deficit as close as possible to 0 so that the system actually clears in terms of payments. As an example, for algorithm RP-C, consider the case where $\lambda_n = \lambda$, $\bar{x}_n = \bar{x}$ for all n , and ϵ_n 's have the identical uniform distribution over the interval $[\epsilon, \epsilon + a]$, i.e. $F_\epsilon(x) = \frac{x-\epsilon}{a}$. Then, setting $\epsilon = -\frac{a\lambda}{\bar{x}}$ ensures that the deficit is 0. On the other hand, for COUP-C, increasing γ decreases the changes in individual consumer loads due to Theorem 4, and consequently the secondary term in (36) decreases. In fact, our simulations show that the LA deficit is fairly small for both RP and COUP. For RP, naively setting $\epsilon_n \sim \mathcal{U}(-\epsilon, \epsilon)$, where ϵ is approximately 1% of the average price, ensures that the deficit is no larger than 0.5% of the payment anticipated by the LA. On the other hand for COUP, setting κ_n to 1 and γ to 1% of the average price increases the consumers' payments by only 0.01% while achieving the desired flat load.

B. Impact of Flexible Consumer Penetration on Supply Cost and Payments

Next, we demonstrate the impact of increasing penetration of flexible consumers on the supply cost and the flexible consumers' payments in Figure 4. We vary the number of flexible consumers in the system while keeping the total load constant. In Figure 4, the arrows indicate the direction that the penetration of flexible consumers increases. We observe that a flexible consumer's payment is greatly reduced compared to the case where it has to serve its demand immediately (i.e. Scheme 1). Furthermore, compared to the amount that they pay under Scheme 2, flexible consumers pay less under RP, and they pay similar or slightly higher under COUP. Thus, we can conclude that consumers significantly benefit from having flexible demand and they will be willing to participate in the new pricing mechanisms to further reduce their payments. Another observation is that payments increase as the number of flexible consumers increases. This is because lower price periods are filled with flexible load, and consequently prices in these periods are not as low as before. As a result, the flexible consumers do not have as much opportunity to take advantage of.

Figure 4 demonstrates that for Scheme 2 there are two regimes in terms of the supply cost. In the first regime, where flexible load is less than 20% of the total load, increasing flexibility reduces the cost, even though Scheme 2 already starts to exhibit abrupt fluctuations in price and total load. A reason for the decrease in cost is the reduced peak load with the increased number of flexible consumers. We also note that our formulation is based on convex cost structure, hence it may not capture efficiently the effect of abrupt fluctuations such as the stress on the network and maintenance costs. However, in the second regime where flexible load is higher




Fig. 4. Algorithms RP and COUP perform better with increasing flexible consumer penetration in the system. In RP, $\epsilon_n(t) \sim \mathcal{U}(-\epsilon, \epsilon)$, where ϵ is set to be 1% of the average of the optimal common price. In COUP, γ is set to be 10% of the average of the common price.

than 20%, fluctuations in load become too large and they are reflected directly in cost under Scheme 2. As far as RP and COUP are concerned, they eliminate the fluctuations, and thus always lead to strictly lower supply cost as the penetration of flexible consumers increases. Due to this reason, the advantage of the proposed algorithms become more apparent when the flexible consumer penetration increases beyond 20% as seen in Figure 4.

VII. CONCLUSION

We proposed two novel real-time dynamic pricing schemes that attempt to solve the volatility problem in a system where economically-driven consumers have the flexibility to defer their demand. We demonstrated the destabilizing effect of opportunistic consumer behavior on the load and the price, when conventional real-time pricing methods are employed.

We propose two new pricing schemes to address this problem. In our first pricing scheme, individual consumers receive different prices that are created by adding small random perturbations to a common price. On the other hand, the second algorithm sets a secondary price for all consumers, along with the common price for consumption. The secondary price penalizes abrupt changes in individual users' consumption. The underlying idea in both proposed algorithms is to create differentiation among consumers so that their aggregate behavior is averaged out over the consumer base. The proposed pricing schemes are simple to implement since they do not require any knowledge on consumer strategies, and they can be employed in various systems other than the smart grid where demand has time flexibilities. Furthermore, in the paper, we numerically demonstrated that self-interested consumers economically benefit from deferring their demand while supply cost for the LA is kept low.

APPENDIX A PROOF OF THEOREM 1

The convergence of the continuous-time algorithm RP-C can be established by using techniques in [20], [21]. To that end, using the KKT conditions for problem (15), it can be shown that the following Lyapunov functions is strictly decreasing:

$$V(t) = \frac{1}{2\alpha}(p(t) - \hat{p})^2 + \frac{1}{2} \sum_n \kappa_n (q_n(t) - \hat{q}_n)^2. \quad (38)$$

APPENDIX B PROOF OF THEOREM 2

First, note the KKT conditions for problem (15):

$$\hat{s} = \sum_n \hat{x}_n + \lambda_S, \quad \hat{p} = \dot{C}(\hat{s}), \quad (39)$$

$$\hat{x}_n = \dot{U}_n^{-1}(\hat{p} - \kappa_n \hat{q}_n), \quad \hat{x}_n \geq \lambda_n, \quad \forall n \quad (40)$$

$$\hat{q}_n(\lambda_n - \hat{x}_n) = 0, \quad \forall n \quad (41)$$

To establish the convergence of RP, we consider the following Lyapunov function and its 1-slot drift:

$$V(t) = \frac{1}{2\alpha}(p(t) - \hat{p})^2 + \frac{1}{2} \sum_n \kappa_n (q_n(t) - \hat{q}_n)^2. \quad (42)$$

After algebraic manipulations, and using the fact that $([y]^+ - z)^2 \leq (y - z)^2$ for $z \geq 0$, the bound on the drift $V(t+1) - V(t)$ is obtained as

$$V(t+1) - V(t) \leq \frac{\alpha}{2} \left(\sum_n x_n(t) + S_i(t) - s(t) \right)^2 \quad (43)$$

$$+ \left(\sum_n x_n(t) + S_i(t) - s(t) \right) (p(t) - \hat{p}) \quad (44)$$

$$+ \sum_n \frac{\kappa_n}{2} (a_n(t) - x_n(t))^2 \quad (45)$$

$$+ \sum_n \kappa_n (a_n(t) - x_n(t))(q_n(t) - \hat{q}_n) \quad (46)$$

Noting that $S_i(t)$, $a_n(t)$, and $\epsilon_n(t)$ are independent of the rest of the variables, we take the expectation of the drift bound w.r.t. their distributions conditional on $p(t)$ and $q_n(t)$. After taking the expectation, we note that (43) and (45) can be bounded as follows:

$$\mathbb{E} \left[\frac{\alpha}{2} \left(\sum_n x_n(t) + S_i(t) - s(t) \right)^2 \middle| p(t), q_n(t) \right] \leq B_1 \quad (47)$$

$$\mathbb{E} \left[\sum_n \frac{\kappa_n}{2} (a_n(t) - x_n(t))^2 \middle| p(t), q_n(t) \right] \leq B_2 \quad (48)$$

where $0 < B_1, B_2 < \infty$, due to the fact that first and second moments of the aforementioned variables are bounded. Furthermore, we have $\mathbb{E}[S_i(t) | p(t), q_n(t)] = \lambda_S$, $\mathbb{E}[a_n(t) | p(t), q_n(t)] = \lambda_n$, and

$$\begin{aligned} \tilde{x}_n(t) &\triangleq \mathbb{E}[x_n(t) | p(t), q_n(t)] \\ &= \mathbb{E}[\bar{x}_n \mathbb{1}\{\epsilon_n(t) \leq \kappa_n q_n(t) - p(t)\} | p(t), q_n(t)] \\ &= \bar{x}_n F_\epsilon(\kappa_n q_n(t) - p(t)) \\ &= u_n(p(t) - \kappa_n q_n(t)) \end{aligned}$$

We also define the conditional expected drift as $\Delta V(t) \triangleq \mathbb{E}[V(t+1) - V(t) | p(t), q_n(t)]$. Using the bounds (47) and (48), and the above expected values, we obtain the bound on $\Delta V(t)$ as

$$\Delta V(t) \leq B_1 + B_2 + \left(\sum_n \tilde{x}_n(t) + \lambda_S - s(t) \right) (p(t) - \hat{p})$$

$$+ \sum_n \kappa_n (\lambda_n - x_n(t))(q_n(t) - \hat{q}_n)$$

Adding and subtracting \hat{x}_n and \hat{s} , using $\hat{s} = \sum_n \hat{x}_n + \lambda_S$, and defining $B_3 \triangleq B_1 + B_2$ we obtain

$$\begin{aligned} \Delta V(t) &\leq B_3 + (p(t) - \hat{p}) \left(\sum_n (\tilde{x}_n(t) - \hat{x}_n) + \hat{s} - s(t) \right) \\ &\quad + \sum_n \kappa_n (q_n(t) - \hat{q}_n) (\lambda_n - \hat{x}_n + \hat{x}_n - \tilde{x}_n(t)) \\ &= B_3 + (p(t) - \hat{p})(\hat{s} - s(t)) \end{aligned} \quad (49)$$

$$+ \sum_n \kappa_n (q_n(t) - \hat{q}_n) (\lambda_n - \hat{x}_n) \quad (50)$$

$$+ \sum_n (\tilde{x}_n(t) - \hat{x}_n) (p(t) - \kappa_n q_n(t) - (\hat{p} - \kappa_n \hat{q}_n)) \quad (51)$$

Now, we treat each term in the above expression separately. For the second term in (49), we apply the mean value theorem and use the strong convexity of C to obtain

$$\begin{aligned} (p(t) - \hat{p})(\hat{s} - s(t)) &= - \left(\dot{C}(s(t)) - \dot{C}(\hat{s}) \right) (s(t) - \hat{s}) \\ &= -\ddot{C}(z)(s(t) - \hat{s})^2 \leq -c_c (s(t) - \hat{s})^2 \end{aligned}$$

where $c_c > 0$ is such that $\ddot{C}(z) \geq c_c > 0$ for all z .

Furthermore, (50) is upper bounded by 0: From complementary slackness condition given in (41), $\hat{q}_n (\lambda_n - \hat{x}_n) = 0$ for all n . Also, $q_n(t) (\lambda_n - \hat{x}_n) \leq 0$ due to dual and primal feasibility. Hence, $(q_n(t) - \hat{q}_n) (\lambda_n - \hat{x}_n) \leq 0$ for all n , and (50) is upper bounded by 0.

Consider (51) in the drift bound. Taking the inverse of the function u_n , we get $p(t) - \kappa_n q_n(t) = u_n^{-1}(\tilde{x}_n(t)) = \dot{U}(\tilde{x}_n(t))$. Furthermore, $\hat{p} - \kappa_n \hat{q}_n = \dot{U}(\hat{x}_n)$ from (40). Plugging the above expressions in (51), applying the mean value theorem, and using the strong concavity of U_n , we obtain

$$\begin{aligned} &\sum_n (\tilde{x}_n(t) - \hat{x}_n) (p(t) - \kappa_n q_n(t) - (\hat{p} - \kappa_n \hat{q}_n)) \\ &= \sum_n (\tilde{x}_n(t) - \hat{x}_n) \left(\dot{U}(\tilde{x}_n(t)) - \dot{U}(\hat{x}_n) \right) \\ &= \sum_n (\tilde{x}_n(t) - \hat{x}_n) \ddot{U}_n(z) (\tilde{x}_n(t) - \hat{x}_n) \\ &\leq -c_u \sum_n (\tilde{x}_n(t) - \hat{x}_n)^2 \end{aligned}$$

where $c_u > 0$ is such that $\ddot{U}_n(z) \leq -c_u < 0$ for all z and n .

Using the bounds that we obtained for the terms (49), (50), and (51) we obtain

$$\Delta V(t) \leq B_3 - c_c (s(t) - \hat{s})^2 - c_u \sum_n (\tilde{x}_n(t) - \hat{x}_n)^2 \quad (52)$$

Then, we take the expectation of the above drift expression w.r.t. $p(t)$ and $q_n(t)$, write it for $t = 0, \dots, T-1$, add both sides of the inequalities, divide by T , and take the limit as $t \rightarrow \infty$ to obtain

$$\begin{aligned} &\lim_{T \rightarrow \infty} \frac{c_u}{T} \sum_{t=1}^{T-1} \sum_n \mathbb{E} [(\tilde{x}_n(t) - \hat{x}_n)^2] \\ &\quad + \lim_{T \rightarrow \infty} \frac{c_c}{T} \sum_{t=1}^{T-1} \mathbb{E} [(s(t) - \hat{s})^2] \leq B_3 \end{aligned} \quad (53)$$

APPENDIX C PROOF OF THEOREM 3

The convergence of the continuous-time algorithm COUP-C can be established by using techniques in (REF). We define $\Theta(t) \triangleq (\mathbf{x}(t), \mathbf{q}(t), p(t), s(t))$ to be the system state at t . Using the KKT conditions for problem (27), we consider the following Lyapunov function:

$$\begin{aligned} V(\Theta(t)) &= \frac{N}{2\alpha} (p(t) - p^*)^2 \\ &\quad + \gamma \left(\sum_n x_n(t) - X^* \right)^2 + \frac{\kappa}{2} \left(\sum_n q_n(t) - Q^* \right)^2 \end{aligned} \quad (54)$$

where Φ^* is given in Definition 1 and achieves the optimal objective of (5). Using similar techniques to the ones in [20], [21], it can be shown that (54) is strictly decreasing, which establishes the theorem's result.

APPENDIX D PROOF OF THEOREM 4

Note the KKT conditions for problem (27):

$$\hat{s} = \sum_n \hat{x}_n + \lambda_S, \quad \hat{p} = \dot{C}(\hat{s}), \quad (55)$$

$$\hat{x}_n = \hat{y}_n, \quad \hat{x}_n \geq \lambda_n, \quad \forall n \quad (56)$$

$$\hat{q}_n (\lambda_n - \hat{x}_n) = 0, \quad \hat{q}_n = \hat{p}, \quad \forall n \quad (57)$$

To establish the convergence result for COUP, we consider the following Lyapunov function and its 1-slot drift:

$$\begin{aligned} V(t) &= \frac{1}{2\alpha} (p(t) - \hat{p})^2 + \frac{1}{2} \sum_n \kappa_n \left(q_n(t) - \frac{\hat{q}_n}{\kappa_n} \right)^2 \\ &\quad + \gamma \sum_n (x_n(t-1) - \hat{x}_n)^2 \end{aligned} \quad (58)$$

Note that the above function is very similar to the one we used in Appendix B in the proof of Theorem 2, except with the edition of the last term. Therefore, following similar steps taken in Appendix B, we obtain the following bound on the conditional expected drift as $\Delta V(t) \triangleq \mathbb{E}[V(t+1) - V(t) | p(t), q_n(t), x_n(t-1)]$:

$$\Delta V(t) \leq B_3 + (p(t) - \hat{p})(\hat{s} - s(t)) \quad (59)$$

$$+ \sum_n \kappa_n \left(q_n(t) - \frac{\hat{q}_n}{\kappa_n} \right) (\lambda_n - \hat{x}_n) \quad (60)$$

$$+ \sum_n (x_n(t) - \hat{x}_n) (p(t) - \kappa_n q_n(t) - (\hat{p} - \hat{q}_n)) \quad (61)$$

$$+ \frac{1}{4\gamma} \sum_n (\kappa_n q_n(t) - p(t))^2 \quad (62)$$

$$+ \sum_n (x_n(t-1) - \hat{x}_n) (\kappa_n q_n(t) - p(t)) \quad (63)$$

Now, we treat each term in the above expression separately.

First, note that, in (61), $(\hat{p} - \hat{q}_n) = 0$ due to (57).

For the second term in (59), applying the mean value theorem and using the strong convexity of C , we obtain

$$(p(t) - \hat{p})(\hat{s} - s(t)) = - \left(\dot{C}(s(t)) - \dot{C}(\hat{s}) \right) (s(t) - \hat{s})$$

$$= -\ddot{C}(z)(s(t) - \hat{s})^2 \leq -c_c(s(t) - \hat{s})^2.$$

Furthermore, (60) is upper bounded by 0 by using the KKT conditions given in (55)-(57)

Using the bounds that we obtained for the terms (59), (60), and combining (61) and (63) together, we obtain

$$\begin{aligned} \Delta V(t) &\leq B_3 - c_c(s(t) - \hat{s})^2 \\ &+ \frac{1}{4\gamma} \sum_n (\kappa_n q_n(t) - p(t))^2 \\ &+ \sum_n (x_n(t) - x_n(t-1)) (p(t) - \kappa_n q_n(t)) \end{aligned} \quad (64)$$

Rearranging the terms and using the update rule for $x_n(t)$, we obtain

$$\Delta V(t) \leq B_3 - c_c(s(t) - \hat{s})^2 - \gamma \sum_n (x_n(t) - x_n(t-1))^2$$

Then, we take the expectation of the above drift expression w.r.t. $p(t)$, $q_n(t)$, and $x_n(t-1)$, write it for $t = 0, \dots, T-1$, add both sides of the inequalities, divide by T , and take the limit as $t \rightarrow \infty$ to obtain

$$\begin{aligned} \lim_{T \rightarrow \infty} \frac{\gamma}{T} \sum_{t=1}^{T-1} \sum_n \mathbb{E} \left[(x_n(t) - x_n(t-1))^2 \right] \\ + \lim_{T \rightarrow \infty} \frac{c_c}{T} \sum_{t=1}^{T-1} \mathbb{E} \left[(s(t) - \hat{s})^2 \right] \leq B_3 \end{aligned} \quad (65)$$

REFERENCES

- [1] T. B. Group. (2007) Quantifying demand response benefits in pjm. [Online]. Available: <http://sites.energetics.com/MADRI/pdfs/brattlegroupepreport.pdf>
- [2] C. Joe-Wong, S. Ha, and M. Chiang, "Time-dependent broadband pricing: Feasibility and benefits," in *Distributed Computing Systems (ICDCS), 2011 31st International Conference on.* IEEE, 2011, pp. 288–298.
- [3] A. J. Conejo, J. M. Morales, and L. Baringo, "Real-time demand response model," *Smart Grid, IEEE Transactions on*, vol. 1, no. 3, pp. 236–242, 2010.
- [4] M. J. Neely, A. S. Tehrani, and A. G. Dimakis, "Efficient algorithms for renewable energy allocation to delay tolerant consumers," in *Smart Grid Communications (SmartGridComm), 2010 First IEEE International Conference on.* IEEE, 2010, pp. 549–554.
- [5] D. Materassi, M. Roozbehani, and M. A. Dahleh, "Equilibrium price distributions in energy markets with shiftable demand," in *Decision and Control (CDC), 2012 IEEE 51st Annual Conference on.* IEEE, 2012, pp. 3183–3188.
- [6] M. Roozbehani, M. A. Dahleh, and S. K. Mitter, "Volatility of power grids under real-time pricing," *Power Systems, IEEE Transactions on*, vol. 27, no. 4, pp. 1926–1940, 2012.
- [7] L. Jiang and S. Low, "Real-time demand response with uncertain renewable energy in smart grid," in *Communication, Control, and Computing (Allerton), 2011 49th Annual Allerton Conference on.* IEEE, 2011, pp. 1334–1341.
- [8] —, "Multi-period optimal energy procurement and demand response in smart grid with uncertain supply," in *Decision and Control and European Control Conference (CDC-ECC), 2011 50th IEEE Conference on.* IEEE, 2011, pp. 4348–4353.
- [9] L. Chen, N. Li, S. H. Low, and J. C. Doyle, "Two market models for demand response in power networks," *IEEE SmartGridComm*, vol. 10, pp. 397–402, 2010.
- [10] A.-H. Mohsenian-Rad, V. W. Wong, J. Jatskevich, R. Schober, and A. Leon-Garcia, "Autonomous demand-side management based on game-theoretic energy consumption scheduling for the future smart grid," *Smart Grid, IEEE Transactions on*, vol. 1, no. 3, pp. 320–331, 2010.

- [11] A.-H. Mohsenian-Rad, V. W. Wong, J. Jatskevich, and R. Schober, "Optimal and autonomous incentive-based energy consumption scheduling algorithm for smart grid," in *Innovative Smart Grid Technologies (ISGT), 2010.* IEEE, 2010, pp. 1–6.
- [12] M. He, S. Murugesan, and J. Zhang, "Multiple timescale dispatch and scheduling for stochastic reliability in smart grids with wind generation integration," in *INFOCOM, 2011 Proceedings IEEE.* IEEE, 2011, pp. 461–465.
- [13] C. Joe-Wong, S. Sen, S. Ha, and M. Chiang, "Optimized day-ahead pricing for smart grids with device-specific scheduling flexibility," *Selected Areas in Communications, IEEE Journal on*, vol. 30, no. 6, pp. 1075–1085, 2012.
- [14] O. Dalkilic, O. Candogan, and A. Eryilmaz, "Pricing algorithms for the day-ahead electricity market with flexible consumer participation," in *Computer Communications Workshops (INFOCOM WKSHPS), 2013 IEEE Conference on.* IEEE, 2013, pp. 369–374.
- [15] S. Chen, P. Sinha, and N. B. Shroff, "Scheduling heterogeneous delay tolerant tasks in smart grid with renewable energy," in *Decision and Control (CDC), 2012 IEEE 51st Annual Conference on.* IEEE, 2012, pp. 1130–1135.
- [16] T. T. Kim and H. V. Poor, "Scheduling power consumption with price uncertainty," *Smart Grid, IEEE Transactions on*, vol. 2, no. 3, pp. 519–527, 2011.
- [17] J. G. Dai, "On positive harris recurrence of multiclass queueing networks: a unified approach via fluid limit models," *The Annals of Applied Probability*, pp. 49–77, 1995.
- [18] X. Lin and N. B. Shroff, "Utility maximization for communication networks with multipath routing," *Automatic Control, IEEE Transactions on*, vol. 51, no. 5, pp. 766–781, 2006.
- [19] PJM. (2014) Historical metered load data. [Online]. Available: <http://www.pjm.com/pub/operations/hist-meter-load/2014-hourly-loads.xls>
- [20] A. Cherukuri, E. Mallada, and J. Cortés, "Asymptotic convergence of constrained primal–dual dynamics," *Systems & Control Letters*, vol. 87, pp. 10–15, 2016.
- [21] S. Meyn, *Control techniques for complex networks.* Cambridge University Press, 2008.

Ozgur Dalkilic received his B.S. and M.S. degrees in Electrical and Electronics Engineering from Bogazici University, Istanbul, in 2006 and 2009, respectively. Now, he is a Ph.D. candidate in Electrical and Computer Engineering at The Ohio State University.

Atila Eryilmaz (S'00 / M'06) received his B.S. degree in Electrical and Electronics Engineering from Bogazici University, Istanbul, in 1999, and the M.S. and Ph.D. degrees in Electrical and Computer Engineering from the University of Illinois at Urbana-Champaign in 2001 and 2005, respectively. Between 2005 and 2007, he worked as a Postdoctoral Associate at the Laboratory for Information and Decision Systems at the Massachusetts Institute of Technology. He is currently an Assistant Professor of Electrical and Computer Engineering at The Ohio State University.

Dr. Eryilmaz research interests include design and analysis for communication networks, optimal control of stochastic networks, optimization theory, distributed algorithms, pricing in networked systems, and information theory. He received the NSF-CAREER and the Lumley Research Awards in 2010.

Xiaojun Lin (S'02 / M'05 / SM'12) received his B.S. from Zhongshan University, Guangzhou, China, in 1994, and his M.S. and Ph.D. degrees from Purdue University, West Lafayette, Indiana, in 2000 and 2005, respectively. He is currently an Associate Professor of Electrical and Computer Engineering at Purdue University.

Dr. Lin's research interests are in the analysis, control and optimization of wireless and wireline communication networks. He received the IEEE INFOCOM 2008 best paper award and 2005 best paper of the year award from Journal of Communications and Networks. His paper was also one of two runner-up papers for the best-paper award at IEEE INFOCOM 2005. He received the NSF CAREER award in 2007. He was the Workshop co-chair for IEEE GLOBECOM 2007, the Panel co-chair for WICON 2008, the TPC co-chair for ACM MobiHoc 2009, and the MiniConference co-chair for IEEE INFOCOM 2012. He is currently serving as an Area Editor for (Elsevier) Computer Networks journal, and has served as a Guest Editor for (Elsevier) Ad Hoc Networks journal, and an Associate Editor for IEEE/ACM Transactions on Networking.